

UC LABORATORY
PO BOX 551
JANESVILLE, MN 56048

Laboratory Results

PHONE- (507)234-5835

REPORT TO: Steele County Public Health
Gabrielle Alvarado
635 Florence Ave
Owatonna, MN 55060

Date Received: 7/11/2024 11:55
Date Printed: 7/12/2024

As Received Temperature: 1 Deg C

Sample Location: **Mineral Springs Fountain**

Laboratory Report # 45484.061

ANALYSES	Sample ID	Result	Units	Method	RL	Date/Time Sampled	Date/Time Analyzed	Lab #	Analyst
Total Coliform	City of Owatonna	Absence		SM 9223 B (Colisure - Presence/Absence)-2016 (23rd Ed)	Presence/Absence	7/10/2024 12:35	7/11/2024 12:25	45484.061	TW/TW
Nitrate as N	City of Owatonna	< 0.05	mg-NO3/L	SM4500-NO3 ⁻ F-16 (23rd Ed)	0.05	7/10/2024 12:35	7/12/2024 10:50	45484.063	CAB/CAB

The sample was absence for Ecoli.
The sample(s) was sampled by the client.
Private wells should be tested at least once a year for bacterial safety.
The state health risk limit for nitrate is 10 mg/L of nitrate-nitrogen.

Approved by ALS 7.12.24



This report cannot be reproduced, except in full, without written approval from UC Laboratory.
The results in this report apply to the samples analyzed in accordance with the Chain-of-Custody record.
UC Laboratory certifies that the test results meet all of the requirements of NELAC.

Unless otherwise noted in the report, the sample conditions at time of receipt met the laboratory's acceptance policy and regulatory requirements.

Your contact person is Amy Schreader

IA Certification # 180 MN Certification # 027-161-186 EPA ID # MN00068