


reinforcement bar used as a grounding method cannot be in soil/fill. It must be encased in concrete

neither of these methods will be approved



Approved means of electrical system grounding